



State Water Resources Control Board

Division of Drinking Water

Lead and Copper Tap Sample Results Reporting Form

This form must be submitted by the public water system to the regulating entity (DDW District Office or County Agency) for each round of lead and copper sampling

Report Date: (mm/dd/yyyy)	08/12/2019
Water System Name:	Sonoma Mountain County Water District
Water System Number:	CA4900580
Water System Type:	<input checked="" type="radio"/> Community <input type="radio"/> Non-Transient, Non Community
Monitoring Frequency:	<input type="radio"/> 6-month <input type="radio"/> Annual <input checked="" type="radio"/> Triennial
# of Samples Required:	5
# of Samples Reported:	5
90th Percentile Level (mg/L)	
Lead: <i>Action Level = 0.015 mg/L</i>	.01175
Copper: <i>Action Level = 1.3 mg/L</i>	.49

	Sample Date	Sample Site Location/Address	Tier 1, 2, 3, or R	Result	
				Lead (mg/L)	Copper (mg/L)
01	07/22/2019	1934 Perth Avenue	1	<.005	<.05
02	07/22/2019	4935 Grange Road	1	<.005	<.05
03	07/22/2019	1965 Skye Avenue	1	<.005	.036
04	07/22/2019	5444 Alta Monte Drive	1	.0085	.240
05	07/22/2019	5441 Alta Monte Drive	1	.015	.740
06					
07					
08					
09					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					